



REVISIONS:

ISSUE DATE:

\_\_\_\_\_

DRAWN BY: JAD

PANDA PROJECT #: S8-20-D7330

ARCH PROJECT #: P7342

A circular professional seal for the State of Alabama. The outer ring contains the text "ALABAMA" at the top and "LICENSED" at the bottom, separated by small vertical tick marks. Inside this ring, the text "No. 38833" is prominently displayed above the word "PROFESSIONAL". At the bottom of the inner circle, the word "ENGINEER" is written above the name "JEFFREY ALAN DEAL". Two small stars are positioned on the left and right sides of the inner circle, flanking the license number.


PANDA EXPRESS

TRUE WARM & WELCOME 2300  
HWY 72 & LINSEY LANE  
ATHENS, AL 35613

M-500


## KITCHEN HOOD DETAILS

TRUE WARM & WELCOME 2300 R1



HOOD SECTIONS	18
---------------	----


Scale: NO SCALE M-50




## CLEAN OUT DOOR DETAIL

---

N.T.S.



(FOR REFERENCE ONLY)



**NOTE:**


1. THE INTEGRITY OF FIRE MASTER DUCT SYSTEMS IS LIMITED TO THE QUALITY OF THE INSTALLATION.
2. REFER TO ICC EVALUATION REPORT 9424E.

FIRE MASTER DUCT WRAP or DUCT WRAP+	
1	DOOR HOLE
2	ACCESS FRAME WELDED TO DUCT
3	1/4" DIA. ALL THREAD RODS
4	ACCESS COVER - 18 GAUGE
5	INSULATION PINS - WELDED
6	ONE LAYER FIRE MASTER DUCT WRAP or DUCT WRAP +
7	ONE LAYER FIRE MASTER DUCT WRAP or DUCTWRAP + 1" OVERLAP
8	ONE LAYER FIRE MASTER DUCT WRAP or DUCTWRAP + 1" OVERLAP
9	SPEED CLIPS
10	ALUMINUM TAPE AT EDGES
11	SPOOL PIECES FOR THREADED RODS
12	1/4" DIA. WING NUTS

GREASE DUCT ACCESS DOOR	2
-------------------------	---

M-500	
-------	--


**NOTE:**  
GREASE EXHAUST DUCT INSULATION TYPE FIRE MASTER  
FASTWRAP+ + SILICON SEALANT APPROVED  
FOR 2-HOUR STRUCTURE.



	LEGEND
1	TWO LAYERS FIRE MASTER FASTWRAP+
2	FILAMENT TAPE
3	BANDING
4	3-INCH PERIMETER OVERLAP
5	3-INCH LONGITUDINAL OVERLAP
6	GREASE DUCT


FOR SI: 1 INCH=25.4 MM

FIGURE 2-HOUR FIRE-RESISTIVE PROTECTION SYSTEM FOR GREASE DUCTS



HOOD CLIP AT WALL	14
-------------------	----

Scale: NO SCALE M-50



## HOOD SUPPORT AT TRUSS | 13

Scale: NO SCALE M-50

HOOD VENTILATION AND SECTION 5

Scale: NO SCALE | M-50

2 HOUR GREASE DUCT WRAP	
-------------------------	--

Scale: NO SCALE M-1