




Revisions:

Mark	Date	By
------	------	----



THIS DOCUMENT IS **"NOT FOR CONSTRUCTION"**
UNLESS THE ARCHITECT OR ENGINEER'S
NAME AND SEAL APPEAR BELOW.

①

EXTERIOR (WEATHER-PROOF)
SINGLE POLE SWITCH ON NOT
COLUMN OF THE DT LANES' C.

EXTERIOR (WEATHER-PROOF)
SINGLE POLE SWITCH ON NOT
COLUMN OF THE DT LANES' C

EXTERIOR (WEATHER-PROOF)
SINGLE POLE SWITCH ON NOT
COLUMN OF THE DT LANES' C

THE DT LANES' CANOPY (OVER THE PHOTOCELL TO TURN LIGHTS OFF) EVEN THOUGH PHOTOCELL IS

THE DT LANES' CANOPY (OVER THE PHOTOCELL TO TURN LIGHTS OFF) EVEN THOUGH PHOTOCELL IS

1

1

USE
BOX
CH)

NO SCALE

1 CEILING LIGHT PROVIDED BY CANOPY SUPPLIER AND
INSTALLED BY E.C.

-
- CANOPY COLUMN
- SINGLE-GANG OPENING (BY THE CANOPY COLUMN SUPPLIER) FOR THE CONTRACTOR FURNISHED RETROFIT SINGLE-GANG BACKBOX TO FLUSH MOUNT IN THE COLUMN FACE (TOWARDS THE ORDERING STATION)
- NOTE: THE SWITCHES AND THE DUPLEX OUTLET ARE TO BE ON THE SIDE OF THE COLUMN FACING THE MENUBOARD (ORDERING POINT) WITH THE LEAST VISIBILITY FOR ONCOMING VEHICLES IN THE DT ORDERING LANES TO SEE THESE ITEMS.
- DEEP SINGLE GANG METAL FLUSH MOUNTED BOX FOR SWITCH OR RECEPTACLE WITH RETROFIT CLIPS AND/OR TABS FOR MOUNTING INTO THE OPENING. SEAL AROUND BOX AFTER INSTALLING ON THE COLUMN (TYPICAL)
- DEEP SINGLE GANG METAL FLUSH MOUNTED BOX FOR THE DUPLEX GFCI RECEPTACLE WITH RETROFIT CLIPS AND/OR TABS FOR MOUNTING INTO THE OPENING. SEAL AROUND BOX AFTER INSTALLING ON THE COLUMN.

NOT TO SCALE

—NEMA 3R JUNCTION BOX ON THE ROOF SIDE OF THE CANOPY CEILING TO TRANSITION FROM THE MC CABLES IN THE COLUMN TO IMC CONDUIT ON THE ROOF TO THE LIGHTS, FANS, AND HEATERS. SEAL THE BOTTOM OF THE BOX TO THE ROOF DECKING.

— GALVANIZED STEEL WITH PVC JACKET
MC CABLES WITHIN THE CANOPY
COLUMN. COORDINATE THE INSTALLATION
(AND LOCATION OF HANDHOLES,
KNOCKOUTS, ETC) WITH THE CANOPY
SUPPLIER AND INSTALLER.

4'-0" SWITCH FOR FANS

5.4. CONTENT EXAMINING

1'-6" GFCI RECEPTACLE

VERIFY INSPECTION ACCESS
CUT-OUT AND PLATE WITH
STRUCTURE DRAWINGS.

0'-0" SIDEWALK
FINISH SLAB

3" PVC CONDUIT CHASE WITH
GALVANIZED STEEL W/ PVC JACKET
MC CABLES TO THE IN-GROUND
PULLBOX'S POWER JUNCTION BOX

CONNECTOR WITH THREADED THROAT
FOR CONNECTION TO THE BACK OF
THE BACKBOX (TYP)

NOT TO SCALE

07-100
Jimmy Carter Blvd
SU #0745

SHEET TITLE
CMD CANOPY
POWER PLAN

17.0522

0745

core : 0743
10.00.17

ate : 10.09.17

Drawn By : MI

Checked By: SN

Sheet

ELIB